



# Declaration of Compliance



# DECLARATION

**Applicant:** Victron Energy B.V.  
De Paal 35  
1351 JG Almere  
The Netherlands

**Product type:** Inverter and battery charger with 2 AC inputs and 2 AC outputs

**Model:** Inverter Quattro-II 48/5000/70-50-50 230V

**Rating:** Input Voltage (Battery): 48 Vdc  
Charge Current (Battery): 70 A  
Discharge Current (Battery): 110 A  
Mains Voltage: 230V 50/60 Hz  
Output Power (off grid): 4000 W / 5000 VA  
Pass through current: 50 A

A representative test sample of above stated model passed the tests according to:

**Standard:** IEC 62109-1:2010 (First Edition)  
IEC 62109-2:2011  
IEC 62040-1:2017  
IEC 60335-2-29:2016, AMD1:2019 for use in conjunction  
IEC 60335-1:2010, COR1:2010, COR2:2011, AMD1:2013,  
COR1:2014, AMD2:2016, COR1:2016  
EN IEC 60335-2-29:2021 + A1:2021 used in conjunction with  
EN 60335 1:2012 + AC:2014 + A11:2014 + A13:2017 +  
A1:2019 + A14:2019 + A2:2019 + A15:2021 EN 62233:2008 +  
AC:2008

**Report no:** 22PP102-01, 22PP102-02, 22PP102-03 und 22PP102-04

**Declaration no:** 23-074-00

**Date of issue:** 2023-03-07

Kiwa Primara GmbH  
Gewerbestraße 28  
87600 Kaufbeuren  
Germany  
Tel. +49 8341 99726-0  
primara@kiwa.com  
www.kiwa.de

Michael Schugg

